# PT/440/0719 - AS (May 2021)

Assessment Schedule for the Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> UV Cure CIPP liner systems as supplied by Brandenburger GmbH & Co. KG



# Independent certification of your products & services

#### 1. SCOPE

This schedule specifies characteristics for the Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> full length UV cured-in-place pipe (CIPP) liner systems as manufactured by Brandenburger GmbH & Co Kg. It is applicable to the renovation of gravity drains and sewers.

The Brandenburger BB<sup>2.5</sup> liner system has a range of internal diameters from 150mm to 1600mm and egg-shaped pipes between 250mm x 375mm (DN250 equivalent) and 1200mm x 1800mm (DN1600mm equivalent) with a maximum wall thickness of 25.2mm.

The Brandenburger BB<sup>1.0</sup> liner system is available in nominal diameters from 150mm to 600mm.

The Brandenburger BB<sup>2.0</sup> liner system is available in nominal diameters from 150mm to 1600mm.

They are not applicable to:

- The installation or reconnection of the laterals.
- Performance of the liner end seals.

### 2. PRODUCT DESCRIPTION

### 2.1 Introduction

All systems comprise of a glass fibre reinforcement woven sleeve which is factory impregnated with an ultra violet (UV) light curing polyester or vinyl ester thermosetting resin. When installed and cured this forms a full length cured-in-place structural liner within the host pipe.

#### 2.2 Relevant Standards

The following relevant standard was identified for cured-in-place liners:

BS EN ISO 11296-4:2018<sup>(1)</sup>

### 2.3 Approval History

This is the first re-approval of the Brandenburger BB<sup>2.5</sup> liner system and first inclusion of the BB<sup>1.0</sup> liner system in March 2021 and the BB<sup>2.0</sup> liner system in May 2021.

 PT/351/0614 (June 2014 and revised December 2016).

This approval supersedes previous issues.

### 3. REQUIREMENTS AND TESTING

### 3.1 Structural Design

The liners can be designed using any of the recognised international design codes dependent upon the country of installation. The Brandenburger default design for the BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> liners is DWA-A143-2<sup>(2)</sup> or ASTM1216-16<sup>(3)</sup>.

#### 3.2 Type Testing

The Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> liner systems shall comply with the following test requirements which are based upon BS EN ISO 11296-4.

Appearance: The internal surface of the lining shall be smooth, clean and free from scoring, cavities, wrinkling and other surface defects that would prevent the Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> liner systems from meeting the general fitness for purpose requirement.

Mechanical Characteristics Testing: Mechanical testing requirements of BS EN ISO 11296-4 are listed in Tables 1, 2 and 3.

© WRc 2021 Contract: 17077-0

Water Research Centre Limited (WRc), Frankland Rd, Blagrove, Swindon SN5 8YF Tel: 01793 865000 Web: www.wrcapproved.com, E-Mail: wrcapproved@wrcplc.co.uk

# PT/440/0719 - AS (May 2021)

Assessment Schedule for the Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> UV Cure CIPP liner systems as supplied by Brandenburger GmbH & Co. KG



# Independent certification of your products & services

Table 1 BB<sup>2.5</sup> liner mechanical characteristics

Parameter	Declared
Short-term flexural modulus DN150-875mm DN 875-1600mm	11,800 MPa 13,600 MPa
Long-term flexural modulus DN150-875mm DN 875-1600mm	9,290 MPa 10,708 MPa
Initial specific ring stiffness DN150-875mm DN 875-1600mm	14,200 MPa 16,875 MPa
Long-term ring stiffness DN150-875mm DN 875-1600mm	11,180 MPa 13,288 MPa
Short-term stress at first break	200 MPa
Long-term stress at first break	157 MPa
Long term strain corrosion test (10,000h)	Minimum: 0.45% Declared: 1.01%

Table 2 BB<sup>1.0</sup> liner mechanical characteristics

Parameter	Declared
Short-term flexural modulus	4,758 MPa
Long-term flexural modulus	2,782 MPa
Initial specific ring stiffness	4,758 MPa
Long-term ring stiffness	2,782 MPa
Short-term stress at first break	115 MPa
Long-term stress at first break	67 MPa
Long term strain corrosion test (10,000h)	Minimum: 0.45% Declared: 1.01%

Table 3 BB<sup>2.0</sup> liner mechanical characteristics

Parameter	Declared
Short-term flexural modulus	9,000 MPa
Long-term flexural modulus	5,806 MPa
Initial specific ring stiffness	8,700 MPa
Long-term ring stiffness	5,600 MPa
Short-term stress at first break	150 MPa
Long-term stress at first break	95 MPa
Long term strain corrosion test (10,000h)	Minimum: 0.45% Declared: 1.01%

Samples are taken each day or from each batch of impregnated linings and cured. The cured sample is tested in accordance with Table 4.

Table 4 BS EN ISO 11296-4 Quality Control tests

Parameter	Requirement
Wall structure	Clause 8.4.2
Wall thickness	Clause 8.4.3
Initial specific ring stiffness or short-term flexural modulus	Clause 8.5.2 Table 5
Flexural stress at first break	Clause 8.5.2 Table 5
Flexural strain at first break	Clause 8.5.2 Table 5

## 3.3 Manufacture

To ensure the quality and performance of Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> liners, the manufacturing process shall include appropriate systems for:

© WRc 2021 Contract: 17077-0 Water Research Centre Limited (WRc), Frankland Rd, Blagrove, Swindon SN5 8YF

Tel: 01793 865000 Web: www.wrcapproved.com, E-Mail: wrcapproved@wrcplc.co.uk

# PT/440/0719 - AS (May 2021)

Assessment Schedule for the Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> UV Cure CIPP liner systems as supplied by Brandenburger GmbH & Co. KG



# Independent certification of your products & services

- Verification of component materials received are to specification.
- Handling and storage of all component materials and finished units.
- · Records of manufacturer.
- Inspection and maintenance of manufacturing equipment.

The production of Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> linings and related Quality Control procedures shall comply with requirements to ensure the stated performance of the product is reliably achieved.

#### 3.4 Installation

When installed in accordance with the installation documentation<sup>(4)</sup>, the installation shall be practicable and suitable for conditions that could reasonably be expected on site.

# 4. APPROVAL

The Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> UV cure CIPP liners have been audited and have successfully met all the requirements stated within this assessment schedule.

Signed:

Valid until 1st July 2024

### 5. REFERENCES

- BS EN ISO 11296 Part 4:2018
   Plastic piping systems for renovation of underground non-pressure drainage and sewerage networks. Part 4 Cured-in-place-pipes.
- DWA-A 143.2- Rehabilitation of drainage systems outside buildings - Part 2: Static calculation for the rehabilitation of wastewater pipes and pipes with lining and assembly methods (July 2015)
- ASTM1216-16 Standard Practice for Rehabilitation of Existing Pipelines and Conduits by the Inversion and Curing of a Resin-Impregnated Tube.
- 4. Installation recommendations for Brandenburger BB<sup>2.5</sup>, BB<sup>1.0</sup> and BB<sup>2.0</sup> CIPP liner, version 1.7 en: August 2020.

© WRc 2021 Contract: 17077-0

Water Research Centre Limited (WRc), Frankland Rd, Blagrove, Swindon SN5 8YF Tel: 01793 865000 Web: www.wrcapproved.com, E-Mail: wrcapproved@wrcplc.co.uk